



Received: 08/09/2011	Completed: 10/03/2011	Letter: S	rb	P.O.#:	Test Report #:	2-88659-0-
----------------------	-----------------------	-----------	----	--------	----------------	------------

Client's Identification	Walltopia Fiberglass Panels. Description: Resin Coating with Orange Colored Paint Applied to Exposed Surface on Fiberglass Panels. (see attached addendum)
-------------------------	--

Tested For: <b>Anastasia Orsova</b> Walltopia LTD 20A Eng Georgi Belov str. Mladost 3, 1712 Sofia, BULGARIA	Key Test: ASTM E 84 (BLDG) 995  Tel: 011 359 2 817 79 48 Fax: 011 359 2 975 60 27
--	--

BLDG: LE 2009; R 04/09; V 4/09  
ASTM E84: LE 2009c; R 11/09; V 11/09

PC: ME /jd

TEST PERFORMED: ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials \*

PRODUCT CATEGORY:

- Textile Type Product
- Vinyl Type Product
- Other than Textile Type or Vinyl Type Product: Fiberglass panels.

\* Note: Textile or expanded vinyl wallcoverings classified by this procedure are limited to use in sprinklered areas in certain public occupancies. If textile or expanded vinyl wallcoverings are used in non-sprinklered areas, a room/corner fire test is mandated, such as NFPA 265 for textiles and NFPA 286 for expanded vinyls.

NFPA 286 test method standard applies not only to expanded vinyls, but also to all non-textile products. Therefore, it should be considered for all interior finish applications in non-sprinklered areas.

SPECIMEN MOUNTING:

- Self Supporting: The test specimen, the face of which was 23" ± 1" x 24', was such that it remained in position in the tunnel during the fire test, and no additional support was required.
- Adhered to IRC: The test specimen was bonded to three 1/4" IRC (Inorganic Reinforced Cement) boards (a cement asbestos substitute) to form a test specimen the face of which was 23" ± 1" x 24'.
- Adhered to Gypsum: The test specimen was adhered to 5/8" thick Type X gypsum board, to form a test specimen the face of which was 23" ± 1" x 24'.
- Unadhered: The 23" ± 1" x 24' specimen was not adhered to any substrate. Instead, it was laid over a 2" hexagonal wire mesh screen and 1/4" rods.
- Other: \_\_\_\_\_